

ADDENDUM NO. 2

TO: Prospective Bidders and Others Concerned

FROM: Lacrechia Bilbrey, PE, CFM - City Engineer

DATE: January 31, 2023

PROJECT: Fire Station Driveway Pad Replacement

OWNER: City of Anderson, South Carolina

BID DATE: February 3rd, 2023

PROJECT NO.: 124803

SUBJECT: *Answers to Questions Received*

EXHIBITS: None

The Contract Documents for this Project are amended as set forth below. Bidders must acknowledge receipt of this Addendum on the Bid Form when bids are submitted.

QUESTIONS

1. Does the curb around the border of the parking lot need to be demolished and replaced or left intact?

Answer: Curb is to be left intact.

2. Will the new parking lot elevation be the same as the existing parking lot? Meaning there will be several inches of subgrade required to be hauled off site to accommodate the 8' of GABC and 9" of concrete?

Answer: Yes, the new pad is to be the same finished elevation as the existing pad.

End of Addendum No. 1