ADDENDUM NO. 1

Branchcliff Lane Streambank Stabilization
City of Anderson, SC
WKD Project No. 20240695.00.WK
City of Anderson Bid No. 2026-10

October 23, 2026

TO ALL BIDDERS:

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents.

Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder.

Bidders and other interested parties are informed that the above-referenced plans, specifications, and contract documents are hereby revised, changed, clarified, and supplemented as set forth below:

PROJECT MANUAL REVISIONS

The Project Manual has been revised as follows:

1. Section 004143, Bid Form, has been revised to include an alternate bid option for ductile iron pipe (DIP).
2. New Section 333113.20, Ductile Iron Gravity Sewer Pipe, has been added.
3. Section 333113.30, Polyvinyl Chloride Gravity Sewer Pipe, has been revised to specify heavy-wall PVC pipe.

IFB PLAN REVISIONS

1. Sheet 3.0 has been amended to clarify that the utility provider shall be responsible for relocating the electrical conflict.
2. Sheet 5.0 has been amended to add a note identifying DIP as an alternate pipe material.

The attached revised Project Manual and IFB Plans incorporate Addendum No. 1 and supersede the previously issued versions of the affected sections and sheets.

QUESTIONS

Questions are due by close of business on October 26, 2026 and may be submitted to akostik@cityofandersonsc.com. Responses will be provided no later than October 28, 2026.

ATTACHMENTS:

1. Revised Project Manual (Incorporates Addendum No. 1)
2. Revised IFB Plans (Incorporates Addendum No. 1)

END OF ADDENDUM NO. 1